Public Works and Environmental Services Department
WATER AND WASTEWATER SERVICES - ENGINEERING
2555 West Copans Road • Pompano Beach, Florida 33369 • 954-831-0745 • FAX 954-831-0798/0925

GUIDELINE FOR WATER DISTRIBUTION SYSTEM DEAD END WATER MAINS

Date: June 29, 2011
Date Last Issued: April 13, 2004
Date First Issued: April 13, 2004

This document approved by the Broward County Water & Wastewater Services Technical Standards Committee.

Steven W. Olnick, P.E, Chair

Every dead end water main will terminate with some method for flushing the water main. Acceptable methods are manual blow off valve, automated blow off valve or fire hydrant. Which method is used will be decided by the engineer of record and the appropriate WWS engineering staff person responsible for the project based on location specific conditions.